

閲覧用記録用紙 (平成29年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二氧化硫濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月(焼却日数) (19日間)			(28日間)																					
最小	31.97		42.73	855		841	193		193	53		50	5		2	18		11	8		1	0.00		0.00
最大	74.24		99.43	891		884	195		195	61		57	16		20	34		15	21		15	0.00		0.00
平均	64.93		94.52	872		869	195		195	57		53	10		7	23		13	11		5	0.00		0.00
5月(焼却日数) (31日間)	(14日間)	(6日間)																						
最小	65.35	39.87	44.15	857	843	861	194	193	195	50	43	50	8	5	4	20	22	13	3	9	5	0.00	0.00	0.00
最大	73.56	75.22	97.17	912	896	874	197	195	195	64	51	53	17	15	5	40	35	14	11	14	6	0.00	0.00	0.00
平均	69.87	69.60	87.60	888	872	869	195	194	195	58	46	51	13	10	5	29	28	13	7	11	5	0.00	0.00	0.00
6月(焼却日数) (21日間)	(30日間)																							
最小	33.11		66.58	871	871		195	194		55	43		5	8		19	17		3	5		0.00	0.00	
最大	71.91	74.46		905	901		195	195		63	56		14	15		33	32		9	13		0.00	0.00	
平均	64.76	70.44		890	890		195	195		58	51		9	11		24	22		5	8		0.00	0.00	
7月(焼却日数) (31日間)	(31日間)																							
最小	61.43	64.37		833	871		195	194		53	46		6	8		17	17		2	7		0.00	0.00	
最大	69.06	73.43		895	909		195	195		62	58		12	12		30	31		10	14		0.00	0.00	
平均	66.28	69.27		873	891		195	195		59	52		9	10		23	22		5	9		0.00	0.00	
8月(焼却日数) (16日間)	(31日間)																							
最小	29.13		32.83	849	861		193	193		58	50		6	4		23	19		5	6		0.00	0.00	
最大	73.63	73.71		902	892		195	195		68	59		11	10		34	33		12	12		0.00	0.00	
平均	63.80	68.77		871	875		195	195		61	54		8	7		27	27		8	8		0.00	0.00	
9月(焼却日数) (30日間)	(23日間)																							
最小	67.49	33.88		857	841		194	194		64	44		5	3		20	23		8	4		0.00	0.00	
最大	74.46	72.03		910	883		195	195		70	59		19	24		42	33		20	9		0.00	0.00	
平均	70.87	67.18		888	861		195	195		68	53		9	10		28	27		14	6		0.00	0.00	
10月(焼却日数) (31日間)	(31日間)																							
最小	64.43	65.86		843	848		193	194		58	54		2	6		21	21		7	2		0.00	0.00	
最大	75.27	74.34		900	894		195	195		72	65		11	19		40	33		22	8		0.00	0.00	
平均	69.94	69.69		866	868		195	195		65	60		6	10		29	27		13	4		0.00	0.00	
11月(焼却日数) (12日間)	(20日間)																							
最小	29.24	30.73		866	859		193	191		61	46		5	2		27	21		13	2		0.00	0.00	
最大	70.14	70.48		898	903		195	195		68	66		10	19		38	43		22	6		0.00	0.00	
平均	58.51	63.84		881	884		194	194		65	58		8	11		35	32		16	4		0.00	0.00	
12月(焼却日数) (29日間)	(31日間)																							
最小	27.39	59.80		879	861		194	194		50	39		3	4		20	20		12	6		0.00	0.00	
最大	70.82	69.45		914	901		195	195		67	53		10	9		31	34		25	10		0.00	0.00	
平均	64.31	65.55		898	882		195	195		58	49		6	7		26	27		19	7		0.00	0.00	
1月(焼却日数) (8日間)	(31日間)	(18日間)																						
最小	30.69	60.61	36.61	871	841	852	195	194	190	49	47	26	3	3	4	17	12	7	13	5	1	0.00	0.00	0.00
最大	68.78	79.22	99.02	884	900	918	195	196	195	55	54	57	6	9	9	25	30	17	17	7	7	0.00	0.00	0.00
平均	58.60	68.66	91.57	877	878	893	195	195	194	52	50	53	5	6	6	20	20	14	15	6	5	0.00	0.00	0.00
2月(焼却日数) (8日間)	(28日間)																							
最小		29.91	88.18		845	881		195	193		47	49		2	3		12	11		7	2	0.00	0.00	0.00
最大		76.49	99.79		888	918		195	195		66	57		7	7		18	15		10	6	0.00	0.00	0.00
平均		66.70	92.88		865	898		195	195		60	55		4	5		15	13		8	3	0.00	0.00	0.00
3月(焼却日数) (10日間)		(27日間)																						
最小	31.82		45.08	864		886	195		194	48		52	1		4	15		12	15		2	0.00		0.00
最大	69.48		99.06	910		915	195		195	63		57	11		7	28		14	30		6	0.00		0.00
平均	62.72		92.10	893		902	195		195	56		54	6		6	22		13	22		4	0.00		0.00

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃
 ・最少とは焼却炉の立上げ又は立下げのため焼却量は通常より少なくなります。